



LEGEND

Grid 1-Tullow Street-C3
 Results - Horizontal Illuminance (lux)
 Eav= 17.83
 Emin= 7.05
 Emax= 33.09
 Emin/Emax= 0.21
 Emin/Eav= 0.40
 Emax/Eav= 1.86

Grid 2- Potato Market
 Results - Horizontal Illuminance (lux)
 Eav= 18.10
 Emin= 7.57
 Emax= 33.31
 Emin/Emax= 0.23
 Emin/Eav= 0.42
 Emax/Eav= 1.84

Grid 3
 Results - Horizontal Illuminance (lux)
 Eav= 17.76
 Emin= 7.11
 Emax= 32.22
 Emin/Emax= 0.22
 Emin/Eav= 0.40
 Emax/Eav= 1.81

Grid 4-Barrack Street Junction
 Results - Horizontal Illuminance (lux)
 Eav= 24.78
 Emin= 14.82
 Emax= 35.33
 Emin/Emax= 0.42
 Emin/Eav= 0.60
 Emax/Eav= 1.43

Luminaire Data
 Luminaire A BPP531 T25 DM50 LED120/- NO
 Lamp LED120-4S/830 MF 0.83

Key

- Luminaire A Column
- Beam Aiming Target
- Photometric Centre

All Dimensions in metres

00	09.12.24	ISSUED FOR INFORMATION
Rev	Date	Amendments







7 Patrick Street
 Kilkenny

LAWLER CONSULTING

Telephone: 056 7721115
 Email: info@lawlerconsulting.com
 Web: www.lawlerconsulting.com

Title

**Carlow Town Centre
 Public Realm and Pedestrian Linkage
 Regeneration Project**

SITE PLAN 1 OF 7

Drawn by:	F.B.	Scale:	1:500 @ A1	Date:	DEC 24
Checked by:	J.C	Drawing no.:	L100-348-TC-0001	Rev.:	00