



NOTES

- This drawing is the property of Carlow County Council, it is a confidential document and must not be copied, used, or its content divulged without prior written consent.
- DO NOT SCALE. use figured dimensions only, if in doubt ask.

LEGEND

SITE OUTLINE —

SITE AREA 0.148 Hect/0.366Acres

EXISTING SPOT LEVELS: ◆ S.L.:266.68

PROPOSED LEVELS: ◆ Prop Level:266.80

Site Centre Coordinates
 X=665138
 Y=672810



No.	Date	Amendment / Issue	App.
A	04/03/24	Planning Stage	LS

CARLOW COUNTY COUNCIL
CONSISTENT COUNCIL CHOICES

CARLOW COUNTY COUNCIL
 HOUSING DEPARTMENT

Director Of Services: Michael Brennan
 Tullow Civic Offices, Inner Relief Road, Tullow, Co. Carlow
 Phone: (059)9136296 Fax: (059)9152156
 Email: secretar@carlowcoco.ie

ENGINEERS IRELAND
 Carlow Local Authorities, A CPD Accredited Company

Project:
PROPOSED NEW DWELLINGS AT TOWNSEND AVENUE, BILBOA, CO. CARLOW.

Title:
SITE PLAN- ESB.

Drawn by:	R.S.	Job No:	
Checked by:	L.S.	Drw Loc:	
Approved by:	LS	Drw. No:	
Scale:	1 to 250 @ A3	Dr. No:	E-108
Date:	04/03/2024	Rev:	A

M&E NOTES

DENOTES EXISTING ESB MINIPILLAR ◆ ESB M.P.◆

DENOTES PROPOSED ESB MINIPILLAR ▲

DENOTES 1No. 125mm Ø RED PVC DUCT WITH STRONG CONTINUOUS 10mm POLYPROPYLENE DRAW ROPE FREE OF KNOTS AND SECURED AT BOTH ENDS. ---

DENOTES 1No. 50mm Ø RED PVC DUCT BETWEEN ESB MINI PILLAR AND DWELLING WITH STRONG CONTINUOUS 10mm POLYPROPYLENE DRAW ROPE FREE OF KNOTS AND SECURED AT BOTH ENDS. ---

STREET LIGHTING

- THE CONTRACTOR MUST INSTALL WARNING TAPE 300mm BELOW GROUND LEVEL ALONG THE FULL LENGTH OF THE NEW DUCT.
- THE CONTRACTOR MUST INSTALL A CONTINUOUS 10mm POLYPROPYLENE DRAW ROPE SECURED AT BOTH ENDS IN THE DUCT.

EXISTING PUBLIC LIGHT. INSTALL NEW PHILIPS HEAD ON EXISTING COLUMN. SINGLE HEAD PHILIPS BGP291 DW50 LED-HB5.2S 73 ●

DENOTES NEW PUBLIC LIGHTING: SINGLE HEAD PHILIPS BGP291 DW50 LED-HB5.2S 730 ON 8M COLUMNS ●

DENOTES 50mm Ø RED PVC DUCT FOR POWER TO LIGHTING WITH STRONG CONTINUOUS 10mm POLYPROPYLENE DRAW ROPE FREE OF KNOTS AND SECURED AT BOTH ENDS. ---

CONTRACTOR TO INCLUDE FOR TESTING AND PROVING OF ALL ELECTRICAL DUCTS. THE CONTRACTOR MUST INSTALL WARNING TAPE 300mm BELOW GROUND LEVEL ALONG THE FULL LENGTH OF THE DUCT.

SITE PLAN-ESB

Scale 1:250